SUBSTITUTE FOR HOUSE BILL NO. 4792

A bill to amend 1994 PA 451, entitled "Natural resources and environmental protection act," by amending section 21106 (MCL 324.21106).

THE PEOPLE OF THE STATE OF MICHIGAN ENACT:

1 Sec. 21106. (1) The Subject to subsection (2), the department 2 of licensing and regulatory affairs shall promulgate rules relating 3 to underground storage tank systems that are at least as stringent as the rules promulgated by the United States environmental 4 protection agency Environmental Protection Agency under subtitle I 5 of title II of Public Law 89-272, 42 U.S.C. USC 6991 to 6991i. 6 7 6991m. These rules shall include a requirement that the owner or operator of an underground storage tank system provide financial 8 responsibility in the event of a release from the underground 9





H02448'19 (H-1)

1 storage tank system.

2 (2) A person shall not operate an unattended self-service
3 motor fuel dispensing facility unless all of the following
4 requirements are met:

5 (a) The person notifies the local fire department at least 306 days before commencing operations.

7 (b) The department of licensing and regulatory affairs
8 approves the facility. The department of licensing and regulatory
9 affairs shall inspect and approve or disapprove the facility within
10 60 days after the operator requests approval.

(3) The department of licensing and regulatory affairs shall
approve the facility under subsection (2) (b) if all of the
following requirements are met:

(a) Fuel pump operating instructions are conspicuously posted
in the dispensing area. The instructions shall include the location
of emergency controls and a requirement that the user remain
outside of the user's vehicle and keep the fuel nozzle in view
during dispensing.

19 (b) The fuel nozzles are automatic-closing nozzles without a20 latch-open device.

(c) For each group of fuel pumps on an island, at least 1
emergency shut-off value that meets all of the following
requirements is provided:

24 (i) Is not less than 20 feet and not more than 100 feet from25 each fuel pump it controls.

26 (*ii*) Is clearly identified and readily accessible.

27

(*iii*) Can be reset only manually.

(d) An approved fire extinguisher for flammable liquids of 4B:C rating or higher is located not more than 100 feet from each



2

fuel pump, is clearly identified or visible, and is readily
 accessible.

3 (e) Warning signs as required by the department of licensing4 and regulatory affairs are posted in the dispensing area.

5 (f) In addition to the warning signs required under 6 subdivision (e), an approved emergency procedures sign is posted in 7 a conspicuous location. The sign shall be of dimensions required by 8 the department of licensing and regulatory affairs and read as 9 follows:

10 IN CASE OF FIRE, SPILL, OR RELEASE

11 1. USE EMERGENCY PUMP SHUTOFF

12 2. REPORT THE ACCIDENT!

13 FIRE DEPARTMENT TELEPHONE NO. _____.

14 FACILITY ADDRESS

15 (g) The dispensing area and area around the emergency controls 16 are well lit.

17 (h) Fuel purchases are not payable by coin or currency.

(i) The fuel pumps do not allow more than \$125.00 of fuel to
be pumped per transaction and require manual action to resume
delivery for the next transaction.

(4) As a condition of approval under subsection (1)(b), the
owner or operator shall visit the site each day and regularly
inspect and maintain the equipment.

(5) The department of licensing and regulatory affairs shall
not require an unattended self-service motor fuel dispensing
facility to limit public access to or dispensing from fuel pumps by
utilizing locked dispensers, security fencing, or other means,
except for means that require payment to be made when fuel is
dispensed.



s 01238 09242019

3